

Memo No:- 255

Date:- 17/03/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : SNP/04835/3/2026 / Private	Sample Details	Date & Time
Sender : sir chhotu ram sr sec school	Collected By	Vivek Tushir
Location : , school	Collection Date	06/03/2026 at 14:55
Sample Description : Drinking Water	Received at lab	06/03/2026 at 14:59
Latitude / Longitude : 77.034100 / 28.893491	Analysis Start Date	06/03/2026
	Analysis End Date	09/03/2026
	Sample Quantity	2 ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.42	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	635	500 mg/lt.	2000 mg/lt.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	249.25	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2340 C
7	Calcium as Ca	75.92	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	14.54	30 mg/lt.	100 mg/lt.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	450	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2320 B
10	Chloride as Cl	49.98	250 mg/lt.	1000 mg/lt.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	104	200 mg/lt.	400 mg/lt.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride as F	1.43	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.09	1.0 mg/lt.	1.0 mg/lt.	USEPA
14	Nitrate as No3	0.6	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	7.18	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :



VIRENDER, CHEMIST
DISTRICT WATER TESTING LABORATORY, SONIPAT
email:-chemist.sonepat@phedharyana.gov.in